

CQI WATER TREATMENT

11 Cindy Lane, Ocean NJ 07712
PO Box 1140 Oakhurst NJ 07755
Phone (732) 493-4002 Fax (732) 493-4425

Domestic Water Lead (Bp) Testing ***Ocean Township School District***

Building	Sample Location	Date	Time	Natl. Standard	Detection Level	Result
Wayside School	Nurses Sink	3/23/16	8:25am	0.015mg/l	15ppb	ND
Wayside School	Cafeteria Sink	3/23/16	8:25am	0.015mg/l	15ppb	ND
Wayside School	Boys Bathroom Sink	3/23/16	8:25am	0.015mg/l	15ppb	ND
Wayside School	Front Hall Fountain	3/23/16	8:25am	0.015mg/l	15ppb	ND
Intermediate School	Nurses Sink	3/23/16	9:20am	0.015mg/l	15ppb	ND
Intermediate School	Science Wing Fountain	3/23/16	9:20am	0.015mg/l	15ppb	ND
Intermediate School	Cafeteria Sink	3/23/16	9:20am	0.015mg/l	15ppb	ND
Intermediate School	Front Hall Fountain	3/23/16	9:20am	0.015mg/l	15ppb	ND
High School	Nurses Sink	3/23/16	9:45am	0.015mg/l	15ppb	ND
High School	Front Hall Fountain	3/23/16	9:45am	0.015mg/l	15ppb	ND
High School	Science Wing Fountain	3/23/16	9:45am	0.015mg/l	15ppb	ND
High School	Cafeteria Sink	3/23/16	9:45am	0.015mg/l	15ppb	ND
Dow Ave School	Cafeteria Sink	3/23/16	10:15am	0.015mg/l	15ppb	ND
Dow Ave School	Front Hall Fountain	3/23/16	10:15am	0.015mg/l	15ppb	ND
Dow Ave School	Nurses Sink	3/23/16	10:15am	0.015mg/l	15ppb	ND
Dow Ave School	Boys Bathroom Fountain	3/23/16	10:15am	0.015mg/l	15ppb	ND

RECEIVED

MAR 24 2016

WATER TREATMENT

Wanamassa School	Cafeteria Sink	3/23/16	10:50am	0.015mg/l	15ppb	ND
School						
Wanamassa School	1 st Floor	3/23/16	10:50am	0.015mg/l	15ppb	ND
School	Fountain					
Wanamassa School	Nurses Sink	3/23/16	10:50am	0.015mg/l	15ppb	ND
School						
Wanamassa School	Boys Bathroom	3/23/16	10:50am	0.015mg/l	15ppb	ND
School	Sink					
Administration Bldg.	Maintenance	3/23/16	11:20am	0.015mg/l	15ppb	ND
School	Fountain					
Administration Bldg.	2 nd Floor	3/23/16	11:20am	0.015mg/l	15ppb	ND
School	Sink					

INDEX: **POS = The level was detected above the minimum detection level**
ND = The level was not detected above the minimum detection level